

for Industrial/Commercial Premises
Requirements for Electrical Installations
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition + Amendments)

A. Details of the Installation

Client	Sample Client	Installation	Sample Site
Address	Sample Address	Address	Sample Address
Postcode	Sample Postcode	Postcode	Sample Postcode

B. Reason for Producing this Report

This form is to be used only for reporting on the condition of an existing installation

To confirm compliance with BS7671 and to assess the suitability and safety of the installation for continued use.

Date(s) on which the inspection and testing were carried out

29-08-2025

C. Details of Installation which is the Subject of this Report

Estimated age of the wiring system	30	Description of premises	Commercial
Evidence of alterations or addition	2 Years		
Records of installation available	No		

D. Extent of Electrical Installation Covered by this Report:

As agreed within the scope of the specification, all main voltage circuits connected to the origin of the supply and all subsequent sub-circuits

Agreed Limitations and Operational Limitations (Regulations 653.2)

STANDARD (PRE-AGREED) LIMITATIONS: 20% Inspection of final distribution circuits and accessories. Continuity of protective conductors and bonding conductors has been undertaken using Method 2 and recorded as an R2 result or calculated from Earth Fault Loop Impedance (EFL). Polarity confirmed using EFL test. IR testing undertaken by connecting L&N and testing to earth. Only accessible points are included. Equipment greater than 3 meters in height not inspected. Equipment that is not accessible (if any) has not been inspected. Cables and equipment below floors, within fabric of building and above ceilings has not been inspected. Tracing of unidentified circuits has not been undertaken and where applicable, has been noted as an FI code on this report. ADDITIONAL LIMITATIONS: No power outage
n/a

Agreed with:

Client

The inspection and testing detailed within this report and accompanying schedule has been carried out in

accordance with BS 7671: 2018 (IET Wiring Regulations) with amendments

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Overall assessment of the installation in terms of its suitability for continued use

UNSATISFACTORY

THE INSTALLATION HAS BEEN DEEMED UNSATISFACTORY DUE TO THE PRESENCE OF CRITICAL OBSERVATIONS

*An UNSATISFACTORY assessment indicates that dangerous (code C1), potentially dangerous (code C2) or further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we

recommend that the installation is further inspected and tested by

26-08-2030

G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules,

Company	Reaction Limited T/A Reaction Group	Inspected and tested by	Authorised for issue by
Address	Midsummer House 314 Midsummer Boulevard Milton Keynes	Name: Mike Crighton	Mike Crighton
Postcode	MK9 2UB	Signature:	
Branch No.	n/a	Position: Lead Engineer	Qualifying Manager
Scheme No	NICEIC: 500091000	Date: 29-08-2025	29-08-2025

ELECTRICAL INSTALLATION CONDITION REPORT

for Industrial/Commercial Premises

H. Supply Characteristics and Earthing Arrangements

Earthing Arrangements

TN-S

☐

TN-C-S

☒

TT

☐

Other

☐

Please specify

Number & Type of live conductors

AC

☒

DC

☐

No. of phases

3

No. of wires

4

Nature of Supply Parameters (Note: (1) by enquiry, (2) by enquiry or by measurement)

Nominal voltage, U/U0 (1)

400/230

v

Nominal frequency, f(1)

50

Hz

Confirmation of supply polarity

TRUE

Prospective fault current, Ipf(2)

7.3

kA

External loop impedance, Ze (2)

0.03

Ω

Supply Protective Device BS (EN)

BS 88

Type

Rated Current

A

I. Particulars of Installation Referred to in this Report

Earth Electrode Location

N/A

Means of Earthing

Distributors Facility

Main Protective Conductors

Material

csa

Earthing Conductor

35

Copper

mm²

Verified

Protective Bonding Conductor

16

Copper

mm²

Verified

Main Switch

Location

INTAKE, MAIN WORKSHOP

Water installation

Verified

To structural steel

N/A

Fuse/device rating or setting

200

A

Voltage rating

400

V

Gas installation pipes

N/A

To lightning protection

N/A

If RCD main switch:

Rated residual operating current I Δn

N/A

mA

Oil installation pipes

N/A

BS(EN)

No. of Poles

Current Rating

A

Rated time delay

N/A

ms

Measured operating trip time

N/A

ms

J. Observations

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results, and subject to the limitations specified at the Extent and limitations of inspection and testing Section D.

Explanation of codes

C1

Danger present. Risk of Injury. Immediate remedial action required

C2

Potentially dangerous. Urgent remedial action required

C3

Improvement recommended

FI

Further Investigation required without delay

Item No.	Observations	Photo	Code
307	IP RATING, DAMAGED ISOLATOR	Photo Link	C2
308	MISSING TRUNKING LID (C2)	Photo Link	C2
309	CABLES NOT MECHANICALLY SUPPORTED IN A FIRE EXIT ROUTE	Photo Link	C2
310	UNSUPPORTED CABLE	Photo Link	C2
312	CABLES NOT MECHANICALLY SUPPORTED IN A FIRE EXIT ROUTE	Photo Link	C2
306	IP RATING, VARIOUS IP RATED SOCKETS AROUND BUILDING ARE MISSING THERE COVER	Photo Link	C3
305	ADDITIONAL PROTECTION - RCD: ADDITIONAL PROTECTION BY MEANS OF AN RCD WITH A RATED RESIDUAL OPERATING CURRENT NOT EXCEEDING 30mA SHALL BE PROVIDED FOR SOCKET OUTLETS NOT EXCEEDING 32A. AN EXCEPTION IS PERMITTED WHERE FOR AN INSTALLATION, OTHER THAN A DWELLING, A DOCUMENTED RISK ASSESSMENT IS PROVIDED. (C3)	Photo Link	C3
311	VARIOUS LIGHTS AROUND THE BUILDING HAVE COME TO THE END OF THEIR USEFUL LIFE	Photo Link	OBS

Created by RG Connect (proprietary inspection software from Reaction Group) © Copyright Reaction Limited 2025.

ELECTRICAL INSTALLATION CONDITION REPORT

for Industrial/Commercial Premises

Outcomes							
Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:	Inadequacies: (Items 1.1 - 1.1.5 Only)
PASS	C1 or C2	C3	FI	N/V	LIM	N/A	INAD
Item No.	Description						Outcome
1.0 INTAKE EQUIPMENT (VISUAL INSPECTION ONLY);							
1.1	Service cable						PASS
1.1.1	Service head						PASS
1.1.2	Earthing arrangement						PASS
1.1.3	Meter tails						PASS
1.1.4	Metering equipment						PASS
1.1.5	Isolator (where present)						PASS
1.1.6	Person ordering work/duty holder notified (Delete as appropriate) NOTE 1 Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority. NOTE 2 For this section only, where inadequacies are found, an X should be put against the appropriate item and a comment made in Section K						N/A
1.2	Consumer's Isolator (where present)						PASS
1.3	Consumer's meter tails						PASS
2.0 PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES							
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)						N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)						N/A
3.0 AUTOMATIC DISCONNECTION OF SUPPLY							
3.1	Main earthing/bonding arrangements (411.3; Chap 54)						
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)						PASS
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)						N/A
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)						PASS
3.1.4	Adequacy of earthing conductor connections (542.3.2)						PASS
3.1.5	Accessibility of earthing conductor connections (543.3.2)						PASS
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)						PASS
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)						PASS
3.1.8	Accessibility of all protective bonding connections (543.3.2)						PASS
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)						PASS
3.2	FELV - requirements satisfied (411.7; 411.7.1)						PASS
4.0 OTHER METHODS OF PROTECTION (where any of the methods listed below are employed details should be provided on separate sheets)							
4.1	Non-conducting location (418.1)						N/A

4.2	Earth-free local equipotential bonding (418.2)	N/A
4.3	Electrical separation (Section 413; 418.3)	N/A
4.4	Double insulation (Section 412)	N/A
4.5	Reinforced insulation (Section 412)	N/A
5.0 DISTRIBUTION EQUIPMENT		
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	PASS
5.2	Security of fixing (134.1.1)	PASS
5.3	Condition of insulation of live parts (416.1)	PASS
5.4	Adequacy/security of barriers (416.2)	PASS
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	PASS
5.6	Condition of enclosure(s) in terms of fire rating etc. (421.1.6; 421.1.201; 526.5)	PASS
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	PASS
5.8	Presence and effectiveness of obstacles (417.2)	PASS
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	PASS
5.10	Operation of main switch(es) (functional check) (643.10)	PASS
5.11	Manual operation of circuit-breakers RCDs and AFDDs to prove functionality (643.10)	PASS
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	PASS
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	N/A
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	N/A
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	PASS
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	FI
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	N/A
5.18	Presence of next inspection recommendation label (514.12.1)	PASS
5.19	Presence of other required labelling (please specify) (Section 514)	N/A
5.20	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	PASS
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	PASS
5.0 DISTRIBUTION EQUIPMENT CONT.		
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	PASS
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	PASS
5.24	Confirmation indication that the SPD is functional (534.1, 651.4)	N/A
6.0 DISTRIBUTION CIRCUITS		
6.1	Identification of conductors (514.3.1)	PASS
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	PASS
6.3	Condition of insulation of live parts (416.1)	PASS
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	PASS
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	C2

6.6	Cables correctly terminated in enclosures (Section 526)	PASS
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	PASS
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	PASS
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	FI
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	PASS
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	PASS
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	PASS
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	C2
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	PASS
6.15 CABLES CONCEALED UNDER FLOORS, ABOVE CEILINGS, IN WALLS/PARTITIONS LESS THAN 50 MM FROM A SURFACE, AND IN PARTITIONS CONTAINING METAL PARTS		
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	LIM
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by cable armour and the like (see Section D. Extent and limitations) (522.6.204)	PASS
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	PASS
6.17	Band II cables segregated/separated from Band I cables (528.1)	PASS
6.18	Cables segregated/separated from non-electrical services (528.3)	PASS
6.19	Condition of circuit accessories (651.2)	PASS
6.20	Suitability of circuit accessories for external influences (512.2)	PASS
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	PASS
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/ record numbers and locations of items inspected (Section 526)	PASS
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	PASS
6.24	General condition of wiring systems (651.2)	PASS
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	PASS
6.26	Confirmation indication that the SPD is functional (534.1, 651.4)	N/A
7.0 CONSUMER UNIT/DISTRIBUTION BOARD		
7.1	Adequacy of working space / accessibility to consumer unit/distribution board (132.12; 513.1)	PASS
7.2	Security of fixing (134.1.1)	PASS
7.3	Condition of enclosure(s) in terms of IP rating (barriers etc.)(416.2)	PASS
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	PASS
7.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	PASS
7.5.1	Presence and effectiveness of obstacles (417.2)	PASS
7.6	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	PASS
7.7	Operation of main switch(es) (functional check) (643.10)	PASS
7.8	Manual operation of circuit-breakers, RCD(s) and AFDD's to prove functionality (643.10)	PASS
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	PASS
7.10	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	N/A

7.11	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	N/A
7.12	Presence of other required labelling (Please specify) Section 514)	N/A
7.13	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	PASS
7.14	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3))	PASS
7.15	Protection against mechanical damage where cables enter distribution board (522.8.1; 522.8.5; 522.8.11)	PASS
7.16	Protection against electromagnetic effects where cables enter distribution board (521.5.1)	PASS
7.17	RCD(s) provided for fault protection – includes RCBO(s)(411.4.204; 411.5.2; 531.2)	N/A
7.18	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	N/A
7.19	Confirmation of indication that SPD is functional (651.4)	N/A
7.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	PASS
7.21	Adequate arrangements where a generating set operates as a switched alternative to public supply (551.6)	N/A
7.22	Adequate arrangements where a generating set operates in parallel with public supply (551.7)	N/A
8.0 FINAL CIRCUITS		
8.1	Identification of conductors (514.3.1)	PASS
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	C2
8.3	Condition of insulation of live parts (416.1)	PASS
8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	PASS
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	C2
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	PASS
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	C2
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	PASS
8.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	PASS
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	PASS
8.10	Cables Concealed Under Floors, Above Ceilings Or In Walls/ Partitions, Adequately Protected Against Damage (522.3.201, 202, 203, 204)	PASS
8.10.1	Installed in prescribed zones (see Section D. Extent and limitation) (522.6.201, 204)	PASS
8.10.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.201; 522.6.204)	PASS
8.12 PROVISION OF ADDITIONAL PROTECTION/REQUIREMENTS BY 30 mA RCD		
8.12.1	For all socket-outlets of rating 32A or less unless an exception is permitted (411.3.3)	C3
8.12.2	For the supply of mobile equipment not exceeding 32A rating for use outdoors (411.3.3)	N/A
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	C3
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	C3
8.12.5	Final circuits supplying luminaries within domestic (household) premises (411.3.4)	N/A
8.12.6	For lighting that is accessible to the public (714.411.3.4)	C3
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	PASS

9.0 FINAL CIRCUITS CONT.

9.14	Band II cables segregated/separated from Band I cables (528.1)	PASS
9.15	Cables segregated/separated from communications cabling (528.2)	PASS
9.16	Cables segregated/separated from non-electrical services (528.3)	PASS
9.17	Terminations of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)	PASS
9.17.1	Connection soundly made and under no undue strain (526.6)	PASS
9.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	PASS
9.17.3	Connections of live conductors adequately enclosed (526.5)	PASS
9.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	PASS
9.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	PASS
9.19	Suitability of accessories for external influences (512.2)	PASS
9.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	PASS
9.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	PASS

10.1 ISOLATOR (SECTIONS 460; 537)

10.1.1	Presence and condition of appropriate devices (Section 462; 537.2.7)	PASS
10.1.2	Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	PASS
10.1.3	Capable of being secured in the OFF position (462.3)	PASS
10.1.4	Correct operation verified (643.10)	PASS
10.1.5	Clearly identified by position and/or durable marking (537.2.6)	PASS
10.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	PASS

10.2 SWITCHING OFF FOR MECHANICAL MAINTENANCE (SECTION 464; 537.3.2)

10.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	PASS
10.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	PASS
10.2.3	Capable of being secured in the OFF position (462.3)	PASS
10.2.4	Correct operation verified (643.10)	PASS
10.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	PASS

10.3 EMERGENCY SWITCHING/STOPPING (SECTION 465; 537.3.3)

10.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	PASS
10.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	PASS
10.3.3	Correct operation verified (643.10)	PASS
10.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	PASS

10.4 FUNCTIONAL SWITCHING (SECTION 463; 537.3.1)

10.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	PASS
10.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	PASS

11.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

11.1	Condition of equipment in terms of IP rating etc (416.2)	PASS
11.2	Equipment does not constitute a fire hazard (Section 421)	PASS
11.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	PASS
11.4	Suitability for the environment and external influences (512.2)	PASS
11.5	Security of fixing (134.1.1)	PASS
11.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	PASS
11.7 RECESSED LUMINAIRES (DOWNLIGHTERS)		
11.7.1	Correct type of lamps fitted (559.3.1)	PASS
11.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	PASS
11.7.3	No signs of overheating to surrounding building fabric (559.4.1)	PASS
11.7.4	No signs of overheating to conductors/terminations (526.1)	PASS
12.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS		
12.1	If any special installations or locations are present, list the particular inspections applied.	N/A
13.0 PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S)		
13.1	Where the installation includes additional requirements and recommendations relating to Chapter 82, additional inspection items should be added to the checklist.	N/A

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name: Sample Client
Client Address: Sample Address
Client Postcode: Sample Postcode
Installation Address: Sample Address
Postcode: Sample Postcode
Distribution Board Details:
SPD Details: Type(s)*: N/A
Location: INTAKE, MAIN WAREHOUSE
Designation: DB1
Supply to distribution board is from: ORIGIN
No. Phases: 3
BS(EN): BS 88 (gG)
Rating: LIM A
Inspection Photographs:
Thermalgraphic Photo: Link
Internal Photo of Board: Link
Completion Image 1: Link
Completion Image 2: Link
Completion Image 3: Link
Completion Image 4: Link

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices		Breaking capacity (KA)	BS 7671 Max. permitted Zs (Ω)	RCD			
				L / N	CPC		BS(EN) Number	Rating (A)			BS(EN) Number	Type No.	IΔn (mA)	Rating (A)
1TP	1ST OVEN RIGHT SIDE	F	C	2.5	2.5	0.4	BS 60898 Type C	20	10	1.09	N/A	N/A	N/A	N/A
2TP	2ND OVEN RIGHT SIDE	G	C	2.5	2.5	0.4	BS 60898 Type C	20	10	1.09	N/A	N/A	N/A	N/A
3L1	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	BENCH SOCKETS	G	C	2.5	2.5	0.4	BS 61009 Type C	20	10	1667.0	61009	C	19.8	20
4TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5TP	SPRAY BOOTH 1	G	C	2.5	2.5	0.4	BS 60898 Type C	20	10	1.09	N/A	N/A	N/A	N/A
6TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7L1	SOCKETS RIGHT HAND WALL	G	C	2.5	2.5	0.4	BS 60898 Type D	20	N/A	0.55	N/A	N/A	N/A	N/A
7L2	#SHOWER RCD UNIT	G	C	6	6	0.4	BS 60898 Type D	20	10	0.55	N/A	N/A	N/A	N/A
7L3	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other. CPC M = Mechanical
* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT

for Industrial/Commercial Premises

Client Name

Sample Client

Client Address

Sample Address

Client Postcode

Sample Postcode

Installation Address

Sample Address

Postcode

Sample Postcode

Distribution board details - Complete in every case

Location

INTAKE, MAIN WAREHOUSE

Designation

DB1

Supply polarity confirmed

PASS

lpf

14.7

kA

Thermalgraphic Photo

Link

Internal Photo of Board

Link

Completion Image 1

Link

Completion Image 2

Link

Completion Image 3

Link

Completion Image 4

Zdb

0.03

Ω

Inspection Photographs

open by clicking links below

SCHEDULE OF TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max Measured Zs (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	Optional <= 30 mA 5 IΔn ms	RCD	AFDD
	r1	m	r2	R1 + R2	R2									
1TP	N/A	N/A	N/A	0.21	N/A	LIM	LIM	LIM	PASS	0.24	N/A	N/A	N/A	N/A
2TP	N/A	N/A	N/A	0.26	0.11	LIM	LIM	LIM	PASS	0.29	N/A	N/A	N/A	N/A
3L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	N/A	N/A	N/A	0.15	N/A	LIM	LIM	LIM	PASS	0.18	19.8	N/A	PASS	N/A
4TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5TP	N/A	N/A	N/A	0.29	0.09	LIM	LIM	LIM	PASS	0.32	N/A	N/A	N/A	N/A
6TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7L1	N/A	N/A	N/A	0.19	N/A	LIM	LIM	LIM	PASS	0.22	N/A	N/A	N/A	N/A
7L2	N/A	N/A	N/A	0.01	0	LIM	LIM	LIM	PASS	0.1	N/A	N/A	N/A	N/A
7L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Test instrument serial number(s)

MG787123

Insulation resistance

MG787123

Continuity

MG787123

RCD

MG787123


Loop impedance

MG787123

E/Electrode

MG787123

Signature



Tested by: Name (capital letters)

MIKE CRIGHTON

Date

29-08-2025

Position

Lead Engineer

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name

Sample Client

Client Address

Sample Address

Client Postcode

Sample Postcode

Installation Address

Sample Address

Postcode

Sample Postcode

Distribution Board Details

SPD Details: Type(s)*

T2

Location

REAR WORKSHOP STORAGE AREA

Designation

DB2

Supply to distribution board is from

ORIGIN

No. Phases

3

BS(EN)

BS 88 (gG)

Rating

63

A

Inspection Photographs

open by clicking links below

Thermalgraphic Photo

Link

Completion Image 1

Link

Completion Image 3

Link

Internal Photo of Board

Link

Completion Image 2

Link

Completion Image 4

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices		Breaking capacity (KA)	BS 7671 Max. permitted Zs (Ω)	RCD			
				L / N	CPC		BS(EN) Number	Rating (A)			BS(EN) Number	Type No.	IΔn (mA)	Rating (A)
1TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	SOCKETS (RING) -	B	B	2.5	2.5	0.4	BS 61009 Type C	32	10	1667.0	61009	A	16.4	32
2L2	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3TP	COMPRESSOR	B	B	6	6	5	BS 60898 Type D	40	10	0.55	N/A	N/A	N/A	N/A
4TP	SURGE PROTECTION	B	B	6	6	5	BS 60898 Type C	63	10	0.35	N/A	N/A	N/A	N/A
5TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L1	SOCKETS	B	B	4	4	0.4	BS 61009 Type C	32	10	1667.0	61009	A	16.4	32
6L2	LIGHTS	B	B	6	6	0.4	BS 60898 Type C	10	10	2.19	N/A	N/A	N/A	N/A
6L3	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7TP	32A SOCKET	B	B	6	6	0.4	BS 60898 Type C	16	10	1.37	N/A	N/A	N/A	N/A
8TP	SPRAY BOOTH	B	B	6	6	0.4	BS 60898 Type C	32	10	0.68	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other. CPC M = Mechanical

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

Created by RG Connect (proprietary inspection software from Reaction Group) © Copyright Reaction Limited 2025.

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name

Sample Client

Client Address

Sample Address

Client Postcode

Sample Postcode

Installation Address

Sample Address

Postcode

Sample Postcode

Distribution board details - Complete in every case

Location

REAR WORKSHOP STORAGE AREA

Designation

DB2

Supply polarity confirmed

PASS

Ip

4.9

kA

Thermalgraphic Photo

Link

Internal Photo of Board

Link

Completion Image 1

Link

Completion Image 2

Link

Completion Image 3

Link

Completion Image 4

Zdb

0.03

Ω

Inspection Photographs

open by clicking links below

SCHEDULE OF TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max Measured Zs (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	Optional <= 30 mA 5 IΔn ms	RCD	AFDD
	r1	m	r2	R1 + R2	R2									
1TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	N/A	N/A	N/A	0.24	0.04	LIM	LIM	LIM	PASS	0.27	16.4	N/A	LIM	N/A
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3TP	N/A	N/A	N/A	0.16	0.07	LIM	LIM	LIM	PASS	0.19	N/A	N/A	N/A	N/A
4TP	N/A	N/A	N/A	0.01	0.09	LIM	LIM	LIM	PASS	0.04	N/A	N/A	N/A	N/A
5TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L1	N/A	N/A	N/A	0.26	0.11	LIM	LIM	LIM	PASS	0.29	16.4	N/A	LIM	N/A
6L2	N/A	N/A	N/A	0.55	0.19	LIM	LIM	LIM	PASS	0.58	N/A	N/A	N/A	N/A
6L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7TP	N/A	N/A	N/A	0.19	0.08	LIM	LIM	LIM	PASS	0.22	N/A	N/A	N/A	N/A
8TP	N/A	N/A	N/A	0.28	0.21	LIM	LIM	LIM	PASS	0.31	N/A	N/A	N/A	N/A

Test instrument serial number(s)

MG787123

Insulation resistance

MG787123

Continuity

MG787123

RCD

MG787123

Loop impedance

MG787123


Tested by: Name (capital letters)

MIKE CRIGHTON

E/Electrode

MG787123

Signature



Position

Lead Engineer

Date

29-08-2025

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name

Sample Client

Client Address

Sample Address

Client Postcode

Sample Postcode

Installation Address

Sample Address

Postcode

Sample Postcode

Distribution Board Details

SPD Details: Type(s)*

N/A

Location

1ST FLOOR REAR

Designation

DB4

Supply to distribution board is from

ORIGIN

No. Phases

3

Inspection Photographs

open by clicking links below

Thermalgraphic Photo

Link

Completion Image 1

Link

Completion Image 3

Link

Internal Photo of Board

Link

Completion Image 2

Link

Completion Image 4

BS(EN)

BS 88 (gG)

Rating

63

A

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices		Breaking capacity (KA)	BS 7671 Max. permitted Zs (Ω)	RCD			
				L / N	CPC		BS(EN) Number	Rating (A)			BS(EN) Number	Type No.	IΔn (mA)	Rating (A)
1L1	SANDER VIA ISOLATOR	B	B	2.5	2.5	0.4	BS 60898 Type B	32	10	1.37	N/A	N/A	N/A	N/A
1L2	SOCKETS - 1ST FLOOR	B	B	6	2.5	0.4	BS 60898 Type C	20	10	1.09	N/A	N/A	N/A	N/A
1L3	LIGHTS - 1ST FLOOR REAR	B	B	1.5	1.5	0.4	BS 60898 Type B	16	10	2.73	N/A	N/A	N/A	N/A
2TP	16A ISOLATOR	B	B	2.5	2.5	0.4	BS 60898 Type C	16	10	1.37	N/A	N/A	N/A	N/A
3TP	1ST FLOOR SPRAY BOOTH	B	B	2.5	2.5	0.4	BS 60898 Type C	10	10	2.19	N/A	N/A	N/A	N/A
4TP	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L1	ISOLATED	B	B	2.5	2.5	0.4	BS 60898 Type B	10	10	4.37	N/A	N/A	N/A	N/A
5L2	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L3	SPARE	N	N	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6TP	WATER HEATER	B	B	2.5	2.5	0.4	BS 60898 Type C	20	10	1.09	N/A	N/A	N/A	N/A

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other. CPC M = Mechanical

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name: Sample Client, Installation Address: Sample Address, Client Address: Sample Address, Client Postcode: Sample Postcode, Postcode: Sample Postcode

Distribution board details - Complete in every case

Location: 1ST FLOOR REAR, Designation: DB4

Thermalgraphic Photo: Link, Completion Image 1: Link, Completion Image 3: Link, Internal Photo of Board: Link, Completion Image 2: Link, Completion Image 4: Link

Supply polarity confirmed: PASS, Ipf: 4.2 kA, Zdb: 0.1 Ω

SCHEDULE OF TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max Measured Zs (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	Optional <= 30 mA 5 IΔn ms	RCD	AFDD
	r1	m	r2	R1 + R2	R2									
1L1	N/A	N/A	N/A	0.12	0.08	LIM	LIM	LIM	PASS	0.22	N/A	N/A	N/A	N/A
1L2	N/A	N/A	N/A	0.2	0.04	LIM	LIM	LIM	PASS	0.30	N/A	N/A	N/A	N/A
1L3	N/A	N/A	N/A	0.16	0.06	LIM	LIM	LIM	PASS	0.26	N/A	N/A	N/A	N/A
2TP	N/A	N/A	N/A	0.18	0.12	LIM	LIM	LIM	PASS	0.28	N/A	N/A	N/A	N/A
3TP	N/A	N/A	N/A	0.16	0.11	LIM	LIM	LIM	PASS	0.26	N/A	N/A	N/A	N/A
4TP	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L1	N/A	N/A	N/A	0.14	0.04	LIM	LIM	LIM	PASS	0.24	N/A	N/A	N/A	N/A
5L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6TP	N/A	N/A	N/A	0.01	n/a	LIM	LIM	LIM	PASS	0.0	N/A	N/A	N/A	N/A

Test instrument serial number(s): MG787123, Insulation resistance: MG787123, Continuity: MG787123, RCD: MG787123

Loop impedance: MG787123

Tested by: Name (capital letters): MIKE CRIGHTON, E/Electrode: MG787123, Signature: [Signature]

Position: Lead Engineer, Date: 29-08-2025

for Industrial/Commercial Premises

SCHEDULE OF CIRCUIT DETAILS

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other. **CPC M** = Mechanical

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.

t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CONDITION REPORT
for Industrial/Commercial Premises

Client Name

Sample Client

Client Address

Sample Address

Client Postcode

Sample Postcode

Installation Address

Sample Address

Postcode

Sample Postcode

Distribution board details - Complete in every case

Location

ABOVE MAIN SUPPLY

Designation

DB OFFICE

Supply polarity confirmed

PASS

Ip

12.5

kA

Thermalgraphic Photo

Link

Internal Photo of Board

Link

Completion Image 1

Link

Completion Image 2

Link

Completion Image 3

Link

Completion Image 4

Zdb

0.03

Ω

Inspection Photographs

open by clicking links below

SCHEDULE OF TEST RESULTS

Circuit No. and Line	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity	Max Measured Zs (Ω)	RCD testing		Manual test button operation	
	Ring final circuits only			R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			All RCDs IΔn ms	Optional <= 30 mA 5 IΔn ms	RCD	AFDD
	r1	m	r2	R1 + R2	R2									
1	N/A	N/A	N/A	0.42	0.05	LIM	LIM	LIM	PASS	0.45	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	0.68	0.16	LIM	LIM	LIM	PASS	0.71	N/A	N/A	N/A	N/A
3	N/A	N/A	N/A	0.6	0.19	LIM	LIM	LIM	PASS	0.63	N/A	N/A	N/A	N/A
4	N/A	N/A	N/A	0.13		LIM	LIM	LIM	PASS	0.16	N/A	N/A	N/A	N/A
5	LIM	LIM	LIM	0.15		LIM	LIM	LIM	PASS	0.18	N/A	N/A	N/A	N/A
6	LIM	LIM	LIM	0.35		LIM	LIM	LIM	PASS	0.38	N/A	N/A	N/A	N/A
7	N/A	N/A	N/A	0.43	0.15	LIM	LIM	LIM	PASS	0.46	N/A	N/A	N/A	N/A
8	N/A	N/A	N/A	0.29	0.09	LIM	LIM	LIM	PASS	0.32	N/A	N/A	N/A	N/A

Test instrument serial number(s)

MG787123

Loop impedance

MG787123

Insulation resistance

MG787123

Continuity

MG787123

RCD

MG787123

Tested by: Name (capital letters)

MIKE CRIGHTON

E/Electrode

MG787123

Signature

Position

Lead Engineer

Date

29-08-2025